



400KV R.S. (O&M) Divn. Lonikand

Telephone nos
1) 02137324488 (CR)
2) 02137324422 (P)
3) 02137324177 (O)

Office of the Executive Engineer
400KV R.S.(O&M)Divn. Lonikand
Tal. Haveli, Dist. Pune
Pin code No. 412 216.

Ref.No.EE/ (O&M)/Dn/LNKD/Tech/

NO 3 2 9 5

Date:- **13 MAR 2012**

TO WHOMSOEVER IT MAY CONCERN

This is to certify that the Winding Temperature and Oil Temperature Indicators Model NO. 1005H with four/two switches, 15 meters capillary length, with built in RTD sensor, CCU and Remote Indicator with 4-20mA DC output as per schematic Drawing. No.6400-74/R2, Range 0-150 Deg. C of M/s Precimeasure Controls Pvt. Limited, Bangalore make were installed at 400 kV R. S. Lonikand of MSETCL in the Year of 2010-2011 and found that all the instruments are working satisfactory since their commissioning.

Bhambhani
Executive Engineer,
400kVR.S. O&M DN,
MSETCL LONIKAND.